499 Jay Windom Martin Residence Hvac Design HVAC Load Calculations

for

499 Jay Windom Martin Residence 6406 Westover Dr. Granbury, TX.



Prepared By:

499 Jay Windom Martin Residence 6406 Westover Dr. Granbury, TX.

Monday, October 13, 2025

Rhvac is an ACCA approved Manual J, D and S computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.

Panshe Enterprice

Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 2

Project Report

General Project Information

Project Filename: C:\Users\User\AppData\Local\Elite Software\Rhvac 10\499 Jay Windom RESIDENCE

basement.r10

Project Title: 499 Jay Windom Martin Residence Hvac Design

Designed By: Engr Rahaman

Project Date: Friday, October 22, 2025

Client Address: 499 Jay Windom Martin Residence
Client City: 6406 Westover Dr. Granbury, TX.
Company Address: 499 Jay Windom Martin Residence
Company City: 6406 Westover Dr. Granbury, TX.

Permit Number(s): HV2025001

Design Data

Reference City: Fort Worth Carswell AFB, Texas

Building Orientation: Front door faces North

Daily Temperature Range: Medium
Latitude: 32 Degrees
Elevation: 650 ft.
Altitude Factor: 0.977

Outdoor Outdoor Outdoor Indoor Indoor Grains Dry Bulb Wet Bulb Rel.Hum Rel.Hum Dry Bulb Difference 30% Winter: 40 20.42 0% 72 46.90 Summer: 100 74 30% 50% 75 21

Check Figures

Total Building Supply CFM: 1,131 CFM Per Square ft.: 0.625
Square ft. of Room Area: 1,810 Square ft. Per Ton: 520

Volume (ft³) (Above Grade): 16,290 Volume (ft³) (Total): 16,290

Building Loads

Total Heating Required Including Ventilation Air:27,111Btuh27.111MBHTotal Sensible Gain:28,644Btuh69%Total Latent Gain:13,089Btuh31%

Total Cooling Required Including Ventilation Air: 41,733 Btuh 3.48 Tons (Based On Sensible + Latent)

Notes

Rhvac is an ACCA approved Manual J, D and S computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.

All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.

Panshe Enterprice Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 3

Load Preview Report

Scope	Has AED	Net Ton	ft.² /Ton	Area	Sen Gain	Lat Gain	Net Gain	Sen Loss	Min Htg CFM	Min Clg CFM	Sys Htg CFM	Sys Clg CFM	Sys Act CFM	
Building		3.48	520	1,810	28,644	13,089	41,733	27,111	286	1,131	286	1,131	1,131	
System 1 Main Floor	Yes	3.48	520	1,810	28,644	13,089	41,733	27,111	286	1,131	286	1,131	1,131	12x17
Ventilation					4,351	5,729	10,081	5,570			405	405	405	
Humidification								12,614						
Zone 1				1,810	24,293	7,360	31,653	8,927	286	1,131	286	1,131	1,131	12x17
1-Basement Mechanical				140	847	0	847	645	21	39	21	39	39	15
2-Basement Theater				300	10,966	6,900	17,866	1,382	44	510	44	510	510	112
3-Basement Storage				130	1,316	0	1,316	608	20	61	20	61	61	15
4-Basement Bedroom				190	3,628	460	4,088	1,836	59	169	59	169	169	18
5-Basement Bathroom				100	1,224	0	1,224	547	18	57	18	57	57	15
6-Basement Flex Room				200	1,612	0	1,612	869	28	75	28	75	75	16
7-Basement Pumproom				490	2,835	0	2,835	1,948	62	132	62	132	132	17
8-Basement Lower Courtyaed				260	1,865	0	1,865	1,092	35	87	35	87	87	16
o-basement Lower Courtyaeu				200	1,003	U	1,003	1,092	33	07	33	07	07	

Panshe Enterprice Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 4


Duct Size Preview

Room or Duct Name	Source	Minimum Velocity	Maximum Velocity	Rough. Factor	Design L/100	SP Loss	Duct Velocity	Duct Length	Htg Flow	Clg Flow	Act. Flow	Duct Size	Reg Size
System 1													
Supply Runouts													
Zone 1													
1-Basement Mechanical	Built-In	0	750	0.01	0.1		288.9		21	39	39	15	
2-Basement Theater	Built-In	0	750	0.01	0.1		649.8		44	510	510	112	
3-Basement Storage	Built-In	0	750	0.01	0.1		449.2		20	61	61	15	
4-Basement Bedroom	Built-In	0	750	0.01	0.1		483.7		59	169	169	18	
5-Basement Bathroom	Built-In	0	750	0.01	0.1		417.8		18	57	57	15	
6-Basement Flex Room	Built-In	0	750	0.01	0.1		382.1		28	75	75	16	
7-Basement Pumproom	Built-In	0	750	0.01	0.1		493.7		62	132	132	17	
8-Basement Lower Courtya	Built-In	0	750	0.01	0.1		442		35	87	87	16	
Other Ducts in System 1													
Supply Main Trunk	Built-In	0	900	0.003	0.1		798		286	1,131	1,131	12x17	

		Summary
System 1		
Heating Flow:	286	
Cooling Flow:	1131	

System 1 - Main Floor - Adequate Exposure Diversity Test

Test For Adequate Exposure Diversity



AED Calculation Summary

--- SYSTEM HAS ADEQUATE EXPOSURE DIVERSITY. ---

System is on N, E, S, W rosette.

Peak load exceeds 12-hour average load by 16.6%.

AED Excursion (amount by which peak exceeds 1.3 x average): 0 Btuh


Definition: A system has adequate exposure diversity if the peak-hour glass load for the entire conditioned space does not exceed the average glass load for the entire conditioned space by more than 30 percent.



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 6

System 1 - Main Floor - Psychrometric Chart

Name	Description	DB	WB	Name	Description	DB	WB
RC	Room Condition	75	62.4	OC	Outdoor Condition	100	74
LC	Leaving Coil Condition	55	52.7	ECC	Entering Coil Condition	78.7	65.3
SD	Supply Duct Gain	n/a	n/a	DTF	Draw-thru Fan S.Gain	n/a	n/a
RD	Return Duct Gain	n/a	n/a	MIX	Mixed Air Point	78.7	65.3
RML	Return Misc Latent	n/a	n/a	ML	Supply Misc Latent	n/a	n/a
RMS	Return Misc Sensible	n/a	n/a	MS	Supply Misc Sensible	n/a	n/a
HRV	Heat Recovery Ventilator	85	69.8				



Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 7

Total Building Summary Loads

Component	Area	Sen	Lat	Sen	Total
Description	Quan	Loss	Gain	Gain	Gain
1G-cm-s: Glazing-Double pane with storm, clear, metal frame no break, U-value 0.55, SHGC 0.62	41	721	0	1,087	1,087
11F: Door-Wood - Solid Core With Metal Storm, U-value 0.28	90	806	0	908	908
Frame wall-R-23: Wall-Frame, Custom, R-23 insulation, U-value 0.043	2110	2,929	0	2,014	2,014
16A-38: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Unvented Attic, No Radiant Barrier, Any Roofing Material, Any Roof Color, R-38 insulation, Uvalue 0.026	1810	1,505	0	3,764	3,764
19A1-11op: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, spray foam insulation, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072	1810	2,966	0	2,316	2,316
Subtotals for structure:		8,927	0	10,089	10,089
People:	32		7,360	9,600	16,960
Equipment:			0	0	0
Lighting:	1350			4,604	4,604
Ductwork:		0	0	0	0
Infiltration: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Ventilation: Winter CFM: 405, Summer CFM: 405		5,570	5,729	4,351	10,081
Humidification (Winter) 34.39 gal/day :		12,614	0	0	0
Total Building Load Totals:		27,111	13,089	28,644	41,733

\sim			_	
	hec	k I	-10	ures
\sim		1		4U1 C3

1,131	CFM Per Square ft.:	0.625
1,810	Square ft. Per Ton:	520
16,290		
16,290		
	1,810 16,290	1,810 Square ft. Per Ton: 16,290

Building Loads

Total Heating Required Including Ventilation Air:	27,111 Btuh	27.111 MBH	
Total Sensible Gain:	28,644 Btuh	69 %	
Total Latent Gain:	13,089 Btuh	31 %	
Total Cooling Required Including Ventilation Air:	41,733 Btuh	3.48 Tons (Based On Sensible + Latent)

Notes

Rhvac is an ACCA approved Manual J, D and S computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.


All computed results are estimates as building use and weather may vary.


Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.

Page 8




Building Pie Chart








Building Bar Graph





Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 10

System 1 Main Floor Summary Loads

Component	Area	Sen	Lat	Sen	Total
Description	Quan	Loss	Gain	Gain	Gain
1G-cm-s: Glazing-Double pane with storm, clear, metal frame no break, U-value 0.55, SHGC 0.62	41	721	0	1,087	1,087
11F: Door-Wood - Solid Core With Metal Storm, U-value 0.28	90	806	0	908	908
Frame wall-R-23: Wall-Frame, Custom, R-23 insulation, U-value 0.043	2110	2,929	0	2,014	2,014
16A-38: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Unvented Attic, No Radiant Barrier, Any Roofing Material, Any Roof Color, R-38 insulation, Uvalue 0.026	1810	1,505	0	3,764	3,764
19A1-11op: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, spray foam insulation, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072	1810	2,966	0	2,316	2,316
Subtotals for structure:		8,927	0	10,089	10,089
People:	32		7,360	9,600	16,960
Equipment:			0	0	0
Lighting:	1350			4,604	4,604
Ductwork:		0	0	0	0
Infiltration: Winter CFM: 0, Summer CFM: 0		0	0	0	0
Ventilation: Winter CFM: 405, Summer CFM: 405		5,570	5,729	4,351	10,081
Humidification (Winter) 34.39 gal/day :		12,614	0	0	0
System 1 Main Floor Load Totals:		27,111	13,089	28,644	41,733

C	ne	CK	Fig	Jur	es

Supply CFM:	1,131	CFM Per Square ft.:	0.625
Square ft. of Room Area:	1,810	Square ft. Per Ton:	520
Volume (ft³) (Above Grade):	16,290		
Volume (ft³) (Total):	16,290		

System Loads

Total Heating Required Including Ventilation Air:	27,111	Btuh	27.111	MBH
Total Sensible Gain:	28,644	Btuh	69	%
Total Latent Gain:	13,089	Btuh	31	%
Total Cooling Required Including Ventilation Air:	41,733	Btuh	3.48	Tons (Based On Sensible + Latent)

Notes

Rhvac is an ACCA approved Manual J, D and S computer program.


Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.


All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.



System 1 Main Floor Pie Chart







499 Jay Windom Martin Residence Hvac Design Page 12



System 1 Main Floor Bar Graph





Panshe Enterprice

Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 13

Equipment Data - System 1 - Main Floor

Cooling

System Type: Standard Air Conditioner

Outdoor Model: Heat Pump:CHPF3743C6+.outdoor unit:GSX160421F

Outdoor Manufacturer: GOODMAN

Description: 0
Capacity: 42,000
Efficiency: 16 SEER

Heating

System Type: Electric Resistance

Model: Heat Pump:CHPF3743C6+.outdoor unit:GSX160421F.

Manufacturer: GOODMAN

Description: 0
Capacity: 42,000
Efficiency: 0%

This system's equipment was selected in accordance with ACCA Manual S.

Manual S equipment sizing data: SODB: 100F, SOWB: 74F, WODB: 40F, SIDB: 75F, SIRH: 50%, WIDB: 72F, Sen. gain: 28,644 Btuh, Lat. gain: 13,089 Btuh, Sen. loss: 27,111 Btuh, Entering clg. coil DB: 84F, Entering clg. coil WB: 66.9F, Entering htg. coil DB: 53.9F, Clg. coil TD: 20F, Htg. coil TD: 70F, Req. clg. airflow: 1131 CFM, Req. htg. airflow: 286 CFM

Panshe Enterprice

Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 14

Manual S Performance Data - System 1 - Main Floor

Loads and Design Conditions

Cooling:

Outdoor Dry Bulb:	100	Sensible Gain:	28.644
Outdoor Wet Bulb:	74	Latent Gain:	13.089
Indoor Dry Bulb:	75	Total Gain:	41.733
Indoor RH:	50	Load SHR:	0.69
Supply Airflow:	1,131	Entering Dry Bulb:	84
		Entering Wet Bulb:	66.9

Heating:

Outdoor Dry Bulb:40Sensible Loss:27.111Indoor Dry Bulb:72Entering Dry Bulb:53.9Indoor RH:30Supply Airflow:286

Equipment Performance Data at System Design Conditions

This system's equipment was selected in accordance with ACCA Manual S.

Cooling:

Model Type: Standard Air Conditioner, Model: Heat Pump:CHPF3743C6+.outdoor unit:GSX160421F. ERV MODEL:

HRV5-150-TPD(27C78)

Nominal Capacity: 42.000, Manufacturer: GOODMAN

Entered Interpolation Data:

EWB	Air Flow	ODB	Total	Power		EDB 84 °F
°F	CFM	°F	Capacity MBtuh	Input kW	S/T	Sensible Capacity MBtuh
66.90942	1131	100	42	0	1	42

Interpolation Results:

			Percent
		<u>Load</u>	of Load
Sensible Capacity:	42.000	28.644	147%
Latent Capacity:	0.000	13.089	0%
Total Capacity:	42.000	41.733	101%

Heating:

Model Type: Electric Resistance, Model: Heat Pump:CHPF3743C6+.outdoor unit:GSX160421F., Nominal Capacity: 42.000, Manufacturer: GOODMAN

Percent


Results:


			1 0100110
		<u>Load</u>	of Load
Heating Capacity:	42.000	27.111	155%



System 1 - Hourly Room Net Gain

System 1 Hourly Room Net Gain





Note: Glass gain as a percent of net gain is shown in parenthesis. Although floor, roof, wall and door gains also vary throughout the day, for this graph and in Manual J glass gains are the only ones that fluctuate.

Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 16

System 1, Zone 1 Summary Loads (Average Load Procedure for Rooms)

-					
Component	Area	Sen	Lat	Sen	Total
Description	Quan	Loss	Gain	Gain	Gain
1G-cm-s: Glazing-Double pane with storm, clear, metal frame no break, U-value 0.55, SHGC 0.62	41	721	0	1,087	1,087
11F: Door-Wood - Solid Core With Metal Storm, U-value 0.28	90	806	0	908	908
Frame wall-R-23: Wall-Frame, Custom, R-23 insulation, U-value 0.043	2110	2,929	0	2,014	2,014
16A-38: Roof/Ceiling-Under Attic with Insulation on Attic Floor (also use for Knee Walls and Partition Ceilings), Unvented Attic, No Radiant Barrier, Any Roofing Material, Any Roof Color, R-38 insulation, Uvalue 0.026	1810	1,505	0	3,764	3,764
19A1-11op: Floor-Over enclosed crawl space, No insulation on exposed walls, sealed or vented space, spray foam insulation, passive, R-11 open cell 1/2 lb. spray foam, 3 inches in 2 x 10 joist cavity, U-value 0.072	1810	2,966	0	2,316	2,316
Subtotals for structure:		8,927	0	10,089	10,089
People: Equipment:	32		7,360 0	9,600 0	16,960 0
Lighting:	1350			4,604	4,604
Ductwork:		0	0	0	0
Infiltration: Winter CFM: 0, Summer CFM: 0		0	0	0	0
System 1, Zone 1 Load Totals:		8,927	7,360	24,293	31,653

Check Figures			
Supply CFM:	1,131	CFM Per Square ft.:	0.625
Square ft. of Room Area:	1,810	Square ft. Per Ton:	686
Volume (ft³) (Above Grade):	16,290	•	
Volume (ft³) (Total):	16,290		

8,927	Btuh	8.927	MBH
24,293	Btuh	77	%
7,360	Btuh	23	%
31,653	Btuh	2.64	Tons (Based On Sensible + Latent)
	24,293 7,360	8,927 Btuh 24,293 Btuh 7,360 Btuh 31,653 Btuh	24,293 Btuh 77 7,360 Btuh 23

Notes

Rhvac is an ACCA approved Manual J, D and S computer program.

Calculations are performed per ACCA Manual J 8th Edition, Version 2.50, and ACCA Manual D.

All computed results are estimates as building use and weather may vary.

Be sure to select a unit that meets both sensible and latent loads according to the manufacturer's performance data at your design conditions.



Elite Software Development, Inc.

499 Jay Windom Martin Residence Hvac Design Page 17

Detailed Room Loads - Room 1 - Basement Mechanical (Average Load Procedure)

General							
Calculation Mode:	Htg. & clg.		Occurrences:			1	
Room Length:	10.0	ft.	System Numb	oer:		1	
Room Width:	14.0	ft.	Zone Number	•		1	
Area:	140.0	sq.ft.	Supply Air:			39 CFM	
Ceiling Height:	9.0	ft.	Supply Air Ch	anges:		1.9 AC/hr	•
Volume:	1,260	cu.ft.	Req. Vent. Cl	g:		75 CFM	
Number of Registers:	1		Actual Winter	Vent.:		29 CFM	
Runout Air:	39	CFM	Percent of Su	pply.:		74 %	
Runout Duct Size:	5	in.	Actual Summ	er Vent.:		14 CFM	
Runout Air Velocity:	289	ft./min.	Percent of Su	pply:		36 %	
Runout Air Velocity:	289	ft./min.	Actual Winter	Infil.:		0 CFM	
Actual Loss:	0.069	in.wg./100 ft.	Actual Summ	er Infil.:		0 CFM	
Item	Ar	ea -U-	Htg	Sen	Clg	Lat	Sen
Description	Quant	ity Value	HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 14 X 9	1	26 0.043	1.4	175	1.0	0	120
E -Wall-Frame wall-R-23 10 X 9		90 0.043	1.4	125	1.0	0	86
UP-Ceil-16A-38 10 X 14	1.	40 0.026	0.8	116	2.1	0	291
Floor-19A1-11op 14 X 10	1.	40 0.072	1.6	229	1.3	0	179
Subtotals for Structure:				645		0	676
Infil.: Win.: 0.0, Sum.: 0.0	2	16	0.000	0	0.000	0	0
Lighting:		50					171
Room Totals:				645		0	847



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 18

Detailed Room Loads - Room 2 - Basement Theater (Average Load Procedure)

General								
Calculation Mode:	tg. & clg.		Occurrences:			1		
Room Length:	10.0	ft.	System Numbe	r:		1		
Room Width:	30.0	ft.	Zone Number:			1		
Area:	300.0	sq.ft.	Supply Air:			510	CFM	
Ceiling Height:	9.0	ft.	Supply Air Char	nges:		11.3	AC/hr	
Volume:	2,700	cu.ft.	Req. Vent. Clg:			330	CFM	
Number of Registers:	1		Actual Winter V	′ent.:		63	CFM	
Runout Air:	510	CFM	Percent of Supp	oly.:		12	%	
Runout Duct Size:	12	in.	Actual Summer	Vent.:		183	CFM	
Runout Air Velocity:	650	ft./min.	Percent of Supp	oly:		36	%	
Runout Air Velocity:	650	ft./min.	Actual Winter Ir	nfil.:		0	CFM	
Actual Loss:	0.102	in.wg./100 ft.	Actual Summer	Infil.:		0	CFM	
Item	Ar	ea -U-	Htg	Sen	Clg	L	_at	
Barrier and the control of the contr	A		LITERA	1	1.1758.4	_		

Item	Area	-U-	Htg	Sen	Clg	Lat	Sen
Description	Quantity	Value	HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 14 X 9	81	0.043	1.4	112	1.0	0	77
E -Wall-Frame wall-R-23 10 X 9	90	0.043	1.4	125	1.0	0	86
N -Door-11F 3 X 8	24	0.280	9.0	215	10.1	0	242
N -Door-11F 3 X 7	21	0.280	9.0	188	10.1	0	212
UP-Ceil-16A-38 10 X 30	300	0.026	0.8	250	2.1	0	624
Floor-19A1-11op 30 X 10	300	0.072	1.6	492	1.3	0	384
Subtotals for Structure:				1,382		0	1,625
Infil.: Win.: 0.0, Sum.: 0.0	216		0.000	0	0.000	0	0
People: 230 lat/per, 300 sen/per:	30					6,900	9,000
Lighting:	100						341
Room Totals:				1,382		6,900	10,966



Elite Software Development, Inc.

499 Jay Windom Martin Residence Hvac Design Page 19

Detailed Room Loads - Room 3 - Basement Storage (Average Load Procedure)

				, ,			,
General							
Calculation Mode:	Htg. & clg.		Occurrences:			1	
Room Length:	10.0	ft.	System Numb	er:		1	
Room Width:	13.0	ft.	Zone Number	•		1	
Area:	130.0	sq.ft.	Supply Air:			61 CFM	
Ceiling Height:	9.0	ft.	Supply Air Ch	anges:		3.1 AC/hi	•
Volume:	1,170	cu.ft.	Req. Vent. Cl			0 CFM	
Number of Registers:	1		Actual Winter	Vent.:		28 CFM	
Runout Air:	61	CFM	Percent of Su	pply.:		45 %	
Runout Duct Size:	5	in.	Actual Summe			22 CFM	
Runout Air Velocity:	449	ft./min.	Percent of Su	pply:		36 %	
Runout Air Velocity:		ft./min.	Actual Winter			0 CFM	
Actual Loss:		in.wg./100 ft.	Actual Summe	er Infil.:		0 CFM	
Item	Ar	ea -U-	Htg	Sen	Clg	Lat	Sen
Description	Quant	ity Value	HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 13 X 9	1	17 0.043	1.4	162	1.0	0	112
E -Wall-Frame wall-R-23 10 X 9		90 0.043	1.4	125	1.0	0	86
UP-Ceil-16A-38 10 X 13	1	30 0.026	0.8	108	2.1	0	270
Floor-19A1-11op 13 X 10	1	30 0.072	1.6	213	1.3	0	166
Subtotals for Structure:				608		0	634
Infil.: Win.: 0.0, Sum.: 0.0	2	07	0.000	0	0.000	0	0
Lighting:	2	00					682
Room Totals:				608		0	1,316



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 20

Detailed Room Loads - Room 4 - Basement Bedroom (Average Load Procedure)

General						
Calculation Mode: Ht	g. & clg.		Occurrences:		1	
Room Length:	10.0	ft.	System Number:		1	
Room Width:	19.0	ft.	Zone Number:		1	
Area:	190.0	sq.ft.	Supply Air:		169	CFM
Ceiling Height:	9.0	ft.	Supply Air Change	es:	5.9	AC/hr
Volume:	1,710	cu.ft.	Req. Vent. Clg:		0	CFM
Number of Registers:	1		Actual Winter Ven	t.:	83	CFM
Runout Air:	169	CFM	Percent of Supply.	:	49	%
Runout Duct Size:	8	in.	Actual Summer Ve	ent.:	60	CFM
Runout Air Velocity:	484	ft./min.	Percent of Supply:		36	%
Runout Air Velocity:	484	ft./min.	Actual Winter Infil.	:	0	CFM
Actual Loss:	0.099	in.wg./100 ft.	Actual Summer In	fil.:	0	CFM
Item	Ar	rea -U-	Htg	Sen Clo	j l	₋at
Description	Quant	tity Value	HTM	Loss HTM	I G	ain

Item	Area	-U-	Htg	Sen	Clg	Lat	Sen
Description	Quantity	Value	HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 19 X 9	85	0.043	1.4	118	1.0	0	81
E -Wall-Frame wall-R-23 10 X 9	90	0.043	1.4	125	1.0	0	86
N -Door-11F 3 X 8	24	0.280	9.0	215	10.1	0	242
N -Door-11F 3 X 7	21	0.280	9.0	188	10.1	0	212
N -Gls-1G-cm-s shgc-0.62 100%S	41	0.550	17.6	721	26.5	0	1,087
UP-Ceil-16A-38 10 X 19	190	0.026	0.8	158	2.1	0	395
Floor-19A1-11op 19 X 10	190	0.072	1.6	311	1.3	0	243
Subtotals for Structure:				1,836		0	2,346
Infil.: Win.: 0.0, Sum.: 0.0	261		0.000	0	0.000	0	0
People: 230 lat/per, 300 sen/per:	2					460	600
Lighting:	200						682
Room Totals:				1,836		460	3,628



Elite Software Development, Inc.

499 Jay Windom Martin Residence Hvac Design Page 21

Detailed Room Loads - Room 5 - Basement Bathroom (Average Load Procedure)

General							
Calculation Mode:	Htg. & clg.		Occurrences:			1	
Room Length:	10.0	ft.	System Numb	oer:		1	
Room Width:	10.0	ft.	Zone Number	r:		1	
Area:	100.0	sq.ft.	Supply Air:			57 CFM	
Ceiling Height:	9.0	ft.	Supply Air Ch	•		3.8 AC/hr	
Volume:	900	cu.ft.	Req. Vent. Cl	•		0 CFM	
Number of Registers:	1		Actual Winter			25 CFM	
Runout Air:	57	CFM	Percent of Su	ıpply.:		44 %	
Runout Duct Size:	5	in.	Actual Summ			20 CFM	
Runout Air Velocity:	418	ft./min.	Percent of Su	ıpply:		36 %	
Runout Air Velocity:	418	ft./min.	Actual Winter	· Infil.:		0 CFM	
Actual Loss:	0.142	in.wg./100 ft.	Actual Summ	er Infil.:		0 CFM	
Item	Are	ea -U-	Htg	Sen	Clg	Lat	Sen
Description	Quant	ity Value	HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 14 X 9		26 0.043	1.4	175	1.0	0	120
E -Wall-Frame wall-R-23 10 X 9	9	90 0.043	1.4	125	1.0	0	86
UP-Ceil-16A-38 10 X 10	10	0.026	8.0	83	2.1	0	208
Floor-19A1-11op 10 X 10	10	0.072	1.6	164	1.3	0	128
Subtotals for Structure:				547		0	542
Infil.: Win.: 0.0, Sum.: 0.0	2	16	0.000	0	0.000	0	0
Lighting:	2	00					682
Room Totals:				547		0	1,224



Elite Software Development, Inc.

499 Jay Windom Martin Residence Hvac Design Page 22

Detailed Room Loads - Room 6 - Basement Flex Room (Average Load Procedure)

General							
Calculation Mode:	Htg. & clg.		Occurrences:			1	
Room Length:	10.0	ft.	System Numb	oer:		1	
Room Width:	20.0	ft.	Zone Number			1	
Area:	200.0	sq.ft.	Supply Air:			75 CFM	
Ceiling Height:	9.0	ft.	Supply Air Ch	anges:		2.5 AC/hr	•
Volume:	1,800	cu.ft.	Req. Vent. Cl	g:		0 CFM	
Number of Registers:	1		Actual Winter	Vent.:		39 CFM	
Runout Air:	75	CFM	Percent of Su	pply.:		53 %	
Runout Duct Size:	6	in.	Actual Summ			27 CFM	
Runout Air Velocity:	382	ft./min.	Percent of Su	pply:		36 %	
Runout Air Velocity:	382	ft./min.	Actual Winter			0 CFM	
Actual Loss:	0.092	in.wg./100 ft.	Actual Summ	er Infil.:		0 CFM	
Item	Ar	ea -U-	Htg	Sen	Clg	Lat	Sen
Description	Quant	ity Value	HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 20 X 9	1	80 0.043	1.4	250	1.0	0	172
E -Wall-Frame wall-R-23 10 X 9		90 0.043	1.4	125	1.0	0	86
UP-Ceil-16A-38 10 X 20	2	0.026	0.8	166	2.1	0	416
Floor-19A1-11op 20 X 10	2	00 0.072	1.6	328	1.3	0	256
Subtotals for Structure:				869		0	930
Infil.: Win.: 0.0, Sum.: 0.0	2	70	0.000	0	0.000	0	0
Lighting:	2	00					682
Room Totals:				869		0	1,612



Elite Software Development, Inc.

499 Jay Windom Martin Residence Hvac Design Page 23

Detailed Room Loads - Room 7 - Basement Pumproom (Average Load Procedure)

General							
Calculation Mode:	Htg. & clg.		Occurrences:			1	
Room Length:	10.0	ft.	System Numb	oer:		1	
Room Width:	49.0	ft.	Zone Number			1	
Area:	490.0	sq.ft.	Supply Air:			132 CFM	
Ceiling Height:			Supply Air Ch	anges:		1.8 AC/h	r
Volume:	4,410	cu.ft.	Req. Vent. CI			0 CFM	
Number of Registers:	1		Actual Winter	•		88 CFM	
Runout Air:	132	CFM	Percent of Su	:.vlagı		67 %	
Runout Duct Size:	7	in.	Actual Summ			47 CFM	
Runout Air Velocity:	494	ft./min.	Percent of Su	ıpplv:		36 %	
Runout Air Velocity:		ft./min.	Actual Winter			0 CFM	
Actual Loss:		in.wg./100 ft.	Actual Summ	er Infil.:		0 CFM	
Item	Ar			Sen	Cla	Lat	Sen
			Htg		Clg		
Description	Quant		HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 49 X 9		41 0.043	1.4	612	1.0	0	421
E -Wall-Frame wall-R-23 10 X 9		90 0.043	1.4	125	1.0	0	86
UP-Ceil-16A-38 10 X 49		90 0.026	0.8	408	2.1	0	1,019
Floor-19A1-11op 49 X 10	4	90 0.072	1.6	803	1.3	0	627
Subtotals for Structure:				1,948		0	2,153
Infil.: Win.: 0.0, Sum.: 0.0	5	31	0.000	0	0.000	0	0
Lighting:	2	00					682
Room Totals:				1,948		0	2,835



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 24

Detailed Room Loads - Room 8 - Basement Lower Courtyaed (Average Load Procedure)

General							
Calculation Mode:	Htg. & clg.		Occurrences:			1	
Room Length:	10.0	ft.	System Numb	oer:		1	
Room Width:	26.0	ft.	Zone Number	•:		1	
Area:	260.0	sq.ft.	Supply Air:			87 CFM	
Ceiling Height:		ft.	Supply Air Ch			2.2 AC/hr	•
Volume:	2,340	cu.ft.	Req. Vent. Cl	g:		0 CFM	
Number of Registers:	1		Actual Winter			50 CFM	
Runout Air:	87	CFM	Percent of Su	ipply.:		57 %	
Runout Duct Size:	6	in.	Actual Summ	er Vent.:		31 CFM	
Runout Air Velocity:	442	ft./min.	Percent of Su	ipply:		36 %	
Runout Air Velocity:		ft./min.	Actual Winter			0 CFM	
Actual Loss:	0.123	in.wg./100 ft.	Actual Summ	er Infil.:		0 CFM	
Item	Ar	ea -U-	Htg	Sen	Clg	Lat	Sen
Description	Quant	ity Value	HTM	Loss	HTM	Gain	Gain
N -Wall-Frame wall-R-23 26 X 9	2	34 0.043	1.4	325	1.0	0	223
E -Wall-Frame wall-R-23 10 X 9	!	90 0.043	1.4	125	1.0	0	86
UP-Ceil-16A-38 10 X 26	2	60 0.026	8.0	216	2.1	0	541
Floor-19A1-11op 26 X 10	2	60 0.072	1.6	426	1.3	0	333
Subtotals for Structure:				1,092		0	1,183
Infil.: Win.: 0.0, Sum.: 0.0	3:	24	0.000	0	0.000	0	0
Lighting:	2	00					682
Room Totals:				1,092		0	1,865

Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc.

499 Jay Windom Martin Residence Hvac Design Page 25

System 1 Room Load Summary

			Htg	Min	Run	Run	Clg	Clg	Min	Act
	Room	Area	Sens	Htg	Duct	Duct	Sens	Lat	Clg	Sys
No	Name	SF	Btuh	CFM	Size	Vel	Btuh	Btuh	CFM	CFM
Zo	ne 1									
1	Basement Mechanical	140	645	21	1-5	289	847	0	39	39
2	Basement Theater	300	1,382	44	1-12	650	10,966	6,900	510	510
3	Basement Storage	130	608	20	1-5	449	1,316	0	61	61
4	Basement Bedroom	190	1,836	59	1-8	484	3,628	460	169	169
5	Basement Bathroom	100	547	18	1-5	418	1,224	0	57	57
6	Basement Flex Room	200	869	28	1-6	382	1,612	0	75	75
7	Basement Pumproom	490	1,948	62	1-7	494	2,835	0	132	132
8	Basement Lower Courtyaed	260	1,092	35	1-6	442	1,865	0	87	87
	Ventilation Humidification		5,570 12,614				4,351	5,729		
	System 1 total	1,810	27,111	286			28,644	13,089	1,131	1,131
_										

System 1 Main Trunk Size: 12x17 in. Velocity: 798 ft./min Loss per 100 ft.: 0.090 in.wg

Cooling System Summary

	Cooling	Sensible/Latent	Sensible	Latent	Total
	Tons	Split	Btuh	Btuh	Btuh
Net Required:	3.48	69% / 31%	28,644	13,089	41,733
Actual:	3.50				42,000

Equipment Data

Latent Capacity:

	<u>Heating System</u>	Cooling System
Type:	Electric Resistance	Standard Air Conditioner
Model:	Heat Pump:CHPF3743C6+.outdoor unit:GSX160421F.	Heat Pump:CHPF3743C6+.outdoor unit:GSX160421F
Indoor Model:		
Brand:		
Description:	0	0
Efficiency:	0%	16 SEER
Sound:	0	0
Capacity:	42,000 Btuh	42,000 Btuh
Sensible Capacity:	n/a	0 Btuh

This system's equipment was selected in accordance with ACCA Manual S.

n/a

Manual S equipment sizing data: SODB: 100F, SOWB: 74F, WODB: 40F, SIDB: 75F, SIRH: 50%, WIDB: 72F, Sen. gain: 28,644 Btuh, Lat. gain: 13,089 Btuh, Sen. loss: 27,111 Btuh, Entering clg. coil DB: 84F, Entering clg. coil WB: 66.9F, Entering htg. coil DB: 53.9F, Clg. coil TD: 20F, Htg. coil TD: 70F, Req. clg. airflow: 1131 CFM, Req. htg. airflow: 286 CFM

0 Btuh

Panshe Enterprice Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 26

Building Rotation Duct Sizes

							Dire	ction Fro	nt doo	r Faces							
Room or	1	V	N	E		E	S	SE	,	S	S	W	V	N	N	W	Max Duct
Duct Name	Htg Flow	Clg Flow	Size														
System 1																	
Supply Runouts																	
Zone 1																	
1-Basement Mechanical	21	39	21	40	21	40	21	40	21	40	21	42	21	42	21	41	15
2-Basement Theater	44	510	44	513	44	522	44	519	44	514	44	539	44	546	44	530	112
3-Basement Storage	20	61	20	62	20	63	20	62	20	62	20	65	20	66	20	64	16
4-Basement Bedroom	59	169	59	223	59	221	59	175	59	170	59	182	59	231	59	231	19
5-Basement Bathroom	18	57	18	57	18	58	18	58	18	57	18	60	18	61	18	59	15
6-Basement Flex Room	28	75	28	75	28	77	28	76	28	76	28	79	28	80	28	78	16
7-Basement Pumproom	62	132	62	133	62	135	62	134	62	133	62	139	62	141	62	137	17
8-Basement Lower Courtyae	35	87	35	87	35	89	35	88	35	87	35	92	35	93	35	90	16
Other Ducts in System 1																	
Supply Main Trunk	286	1,131	286	1,190	286	1,204	286	1,153	286	1,139	286	1,197	286	1,260	286	1,229	12x17
Bldg. High Dir.: North																	
Sensible Gain: 28,644																	
Latent Gain: 13,089																	

_				
S	ur	nr	na	ı۲

System 1

Heating Flow: 286 Cooling Flow: 1131 Dhaka, Bangladesh, BSMRMU 1212



Elite Software Development, Inc. 499 Jay Windom Martin Residence Hvac Design Page 27

Building Rotation Report

All rotation degree values in this report are clockwise with respect to the project's original orientation. Building orientation as entered (zero degrees rotation): Front door faces North

Indivi	dual Rooms									
		0°	45°	90°	135°	180°	225°	270°	315°	High
Rm.	Room	Rot.	Duct							
No.	Name	CFM	Size							
Syste	em 1:									
Zon	e 1:									
1	Basement Mechanical	39	40	40	40	40	42	*42	41	15
2	Basement Theater	510	513	522	519	514	539	*546	530	112
3	Basement Storage	61	62	63	62	62	65	*66	64	16
4	Basement Bedroom	169	223	221	175	170	182	*231	231	19
5	Basement Bathroom	57	57	58	58	57	60	*61	59	15
6	Basement Flex Room	75	75	77	76	76	79	*80	78	16
7	Basement Pumproom	132	133	135	134	133	139	*141	137	17
8	Basement Lower Courtyaed	87	87	89	88	87	92	*93	90	16


^{*} Indicates highest CFM of all rotations.

Rotation	Front door	Supply	Sensible	Latent	Net
Degrees	Faces	CFM	Gain	Gain	Tons
0°	North	1,131	28,644	*13,089	3.48
45°	Northeast	1,190	29,929	13,089	3.58
90°	East	1,204	30,230	13,089	3.61
135°	Southeast	1,153	29,130	13,089	3.52
180°	South	1,139	28,831	13,089	3.49
225°	Southwest	1,197	30,073	13,089	3.60
270°	West	*1,260	*31,435	13,089	*3.71
315°	Northwest	1,229	30.768	13,089	3.65



Building Rotation Report (cont'd)


Building Rotation Tonnage



Building Net Tonnage

Building Rotation Report (cont'd)

Building Rotation Hourly Net Gain







Form RPER 1.01 8 Mar 10

County, Town, Municipality, Jurisdiction Header Information

	Header IIIIOIII		ATTACHED				
Contractor John Doe		REQUIRED ATTACHMENTS Manual J1 Form (and supporting					
Mechanical License # 12345		or MJ1AE Form² (and supporting worksheets): Yes No X					
Building Plan #		OEM performance data (heating, Manual D Friction Rate Workshe	et: Yes No X				
Home Address (Street or Lot#, Block,	, Subdivision)	Duct distribution system sketch:	Yes No X				
HVAC LOAD CALCULATIO	N (IRC M1401.3)						
Design Conditions		Building Construction Infor	mation				
Winter Design Conditions	=	Building					
Outdoor temperature	<u>40</u> °F	Orientation (Front door faces)	North				
Indoor temperature	72 °F		st, Northwest, Southeast, Southwest				
Total heat loss	27111 Btu/h	Number of bedrooms	1				
Summer Design Conditions		Conditioned floor area	1810 Sq Ft				
Outdoor temperature	100 °F	Number of occupants	32				
Indoor temperature	75 °F	Windows	Poof 4				
Grains difference 21 \triangle	Gr @ <u>50</u> % Rh	Eave overhang depth	4 Ft Roof				
Sensible heat gain	28644 Btu/h	Internal shade	Eave Π				
Latent heat gain	13089 Btu/h	Blinds, drapes, etc	Depth Window				
Total heat gain	41733 Btu/h	Number of skylights	<u> </u>				
HVAC EQUIPMENT SELEC	TION (IRC M1401.3)						
Heating Equipment Data	Cooling Equipme	ent Data	Blower Data				
	Resistance Equipment type	Standard Air Conditioner	Heating CFM 1131 CFM				
Furnace, Heat pump, Boiler, etc. eat PMMp:CHPF3743C6+.outdoor unit	Air Conditioner, Heat p	•	<u> </u>				
			Cooling CFM 1131 CFM				
Heating output capacity 42 Heat pumps - capacity at winter design outdoor of	Btu/h Sensible cooling ca	12000					
Auxilians boot output conscitu	Latent cooling capa	<u> </u>					
Auxiliary heat output capacity	Btu/h Total cooling capac	12000	I				
HVAC DUCT DISTRIBUTION	N SYSTEM DESIGN (IRC N	·					
Design airflow	CFM Longest supply duct:	1 L	terials Used (circle) uct: Duct board, Flex, Sheet metal,				
External Static Pressure (ESP)	IWC Longest return duct:	Ft	Lined sheet metal, Other (specify)				
Component Pressure Losses (CPL)	IWC Total Effective Leng	th (TEL) Ft Branch I	Duct: Duct board, Flex, Sheet metal,				
Available Static Pressure (ASP) ASP = ESP - CPL	IWC Friction Rate:	IWC	Lined sheet metal, Other (specify)				
I declare the load calculation, equipn	,	•	sed on the building plan listed				
above, I understand the claims mad	e on these forms will be subject to re	eview and verification.					
Contractor's Printed Name John	n Doe	Date					
Contractor's Signature	Doe						
							

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.



Form RPER 1.01 8 Mar 10

County, Town, Municipality, Jurisdiction **Header Information**

Contractor				REQUIRED	O ATTAC	HMENTS ¹		ATTACHED)
Mechanical License #				or MJ1AE F	orm² (and	supporting we supporting we heating or	,	No 🗌	
Building Plan #				•	riction Rate	e Worksheet:	,	No 🗌	
Home Address (Street or Lot#, Blo	ck, Subdivisior	า)		Duct distribe	ilion syste	III SKOIOII.	163	S NO	
HVAC LOAD CALCULATI	ON (IRC M	1140	1.3)						
Design Conditions			<u>Buil</u>	lding Con	struction	on Inform	ation_		
Winter Design Conditions				Building					
Outdoor temperature		°I	F C	Orientation (F		′ –			_
Indoor temperature		°I		North, East, Number of be		uth, Northeast,	Northwest, Southeas	st, Southwest	
Total heat loss		Btu	u/h			-			
Summer Design Conditions			(Conditioned	floor area		Sq Ft		
Outdoor temperature		°I	F N	Number of oc	ccupants	_			
Indoor temperature		°I	F v	Vindows				Roof _	
Grains difference	∆ Gr @	% RI	h E	Eave overhai	ng depth		Ft	1,001	
Sensible heat gain		Btu	ı/h	nternal shad	е			Eave	
Latent heat gain		Btu	u/h	Blinds, drapes	, etc			Depth Wind	ow
Total heat gain		Btu	ı/h N	Number of sk	kylights	_		T	
HVAC EQUIPMENT SELE	CTION (IF	RC N	M1401.3)						
Heating Equipment Data		<u>(</u>	Cooling Equipment	t Data			Blower Data		_
Equipment type		_	Equipment type				Heating CFM	С	FM
Furnace, Heat pump, Boiler, etc. Model			Air Conditioner, Heat pump, Model	, etc			ricating or w		
		_					Cooling CFM	C	FM
Heating output capacity Heat pumps - capacity at winter design outdo		u/h	Sensible cooling capac			Btu/h			
			Latent cooling capacity	· 		Btu/h			
Auxiliary heat output capacity		u/h	Total cooling capacity			Btu/h			
HVAC DUCT DISTRIBUTI	ON SYSTE	EM D	DESIGN (IRC M16	601.1)					
Design airflow	CFM	/ 1	Longest supply duct:		Ft		rials Used (circle		
External Static Pressure (ESP)	IW0	C I	Longest return duct:		Ft	Trunk Duc	t: Duct board, Flo Lined sheet m	ex, Sheet metal, etal, Other (spec	cify)
Component Pressure Losses (CPL)	IW	C ·	Total Effective Length (TEL)	Ft	Branch Du	ct: Duct board F	Flex, Sheet metal,	—
Available Static Pressure (ASP)	IW	С	Friction Rate:		IWC	Branch Bu		netal, Other (spe	
ASP = ESP - CPL			Friction Rate = (ASP × 100)	÷ TEL	-				
I declare the load calculation, equi above, I understand the claims m						ormed base	ed on the buildin	ng plan listed	
Contractor's Printed Name						Date			
Contractor's Signature						-			

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.



Form RPER 1.01 8 Mar 10

County, Town, Municipality, Jurisdiction Header Information

Contractor John Doe		REQUIRED ATTACHMENTS ¹	ATTACHED worksheets): Yes□ No⊠			
Mechanical License # 12345		or MJ1AE Form² (and supporting worksheets): Yes No 🗵				
Building Plan #		OEM performance data (heating, Manual D Friction Rate Workshee	et: Yes No 🗵			
Home Address (Street or Lot#, Block, Subdi	vision)	Duct distribution system sketch:	Yes☐ No ☒			
HVAC LOAD CALCULATION (UI	MC 1106.1)					
Design Conditions		ilding Construction Inform	mation_			
Winter Design Conditions		Building	NI (I			
Outdoor temperature	<u>40</u> °F	Orientation (Front door faces)	North			
Indoor temperature	<u>72</u> °F	North, East, West, South, Northeas Number of bedrooms	t, Northwest, Southeast, Southwest			
Total heat loss	11 Btu/h		1040 Sa Ft			
Summer Design Conditions		Conditioned floor area	1810 Sq Ft			
Outdoor temperature1		Number of occupants	32_			
Indoor temperature	<u>75</u> °F	Windows	Roof _			
Grains difference $21 \triangle Gr @$	50 % Rh	Eave overhang depth	4 Ft			
Sensible heat gain	344 Btu/h	Internal shade	Eave Π			
Latent heat gain130)89 Btu/h	Blinds, drapes, etc	Depth Window			
Total heat gain 417	'33 Btu/h	Number of skylights	<u>0</u>			
HVAC EQUIPMENT SELECTION						
Heating Equipment Data	Cooling Equipmer	nt Data	Blower Data			
Equipment type Electric Resis	Equipment type Air Conditioner, Heat pum	Standard Air Conditioner	Heating CFM 1131 CFM			
Furnace, Heat pump, Boiler, etc. Heat PMMPCHPF3743C6+.outdoor unit:GSX	•					
Heating output capacity 42000	Btu/h Sensible cooling capa	1000	Cooling CFM 1131 CFM			
Heat pumps - capacity at winter design outdoor conditions	Latent cooling capacit					
Auxiliary heat output capacity	Btu/h Total cooling capacity	40000				
HVAC DUCT DISTRIBUTION SY						
		Dunt Met	rerials Used (circle)			
Design airflow	CFM Longest supply duct:	Г	ct: Duct board, Flex, Sheet metal,			
External Static Pressure (ESP)	IWC Longest return duct:	Ft	Lined sheet metal, Other (specify)			
Component Pressure Losses (CPL)	IWC Total Effective Length	(TEL) Ft Branch D	uct: Duct board, Flex, Sheet metal,			
Available Static Pressure (ASP) ASP = ESP - CPL	IWC Friction Rate: Friction Rate = (ASP × 100) ÷ TEL	Lined sheet metal, Other (specify)			
I declare the load calculation, equipment se above, I understand the claims made on the			sed on the building plan listed			
Contractor's Printed Name John Doe	•	Date				
Contractor's Signature John Doe						

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.



Form RPER 1.01 8 Mar 10

County, Town, Municipality, Jurisdiction **Header Information**

Contractor		REQUIRED ATTA	orkeheets): Voo	ATTACHED				
Mechanical License #		Manual J1 Form (and supporting worksheets): Yes No or MJ1AE Form² (and supporting worksheets): Yes No						
Building Plan #			 OEM performance d Manual D Friction Ra 					
Home Address (Street or Lot#, Block,	Subdivision)		 Duct distribution syst 	tem sketch:	Yes	□ No □		
HVAC LOAD CALCULATION	V (UMC 11	ne 1)						
Design Conditions	V (OWO 110		Building Construct	tion Inform	nation			
Winter Design Conditions			Building					
Outdoor temperature		°F	Orientation (Front do	or faces)				
Indoor temperature		°F			Northwest, Southeast,	Southwest		
Total heat loss	В	tu/h	Number of bedrooms					
Summer Design Conditions			Conditioned floor are	ea	Sq Ft			
Outdoor temperature		°F	Number of occupants	S				
Indoor temperature		°F	Windows			Dest		
Grains difference △ (Gr @ %	Rh	Eave overhang depth	า	Ft	Roof		
Sensible heat gain	В	tu/h	Internal shade			← ∐ ave ∏		
Latent heat gain	В	tu/h	Blinds, drapes, etc			Depth Window		
Total heat gain	В	tu/h	Number of skylights	-		T		
HVAC EQUIPMENT SELEC	TION							
Heating Equipment Data		Cooling Equipn	nent Data		Blower Data			
Equipment type		Equipment type			Heating CEM	CFM		
Furnace, Heat pump, Boiler, etc.		Air Conditioner, Hear	t pump, etc		Heating CFM _			
Model					Cooling CFM _	CFM		
Heating output capacity Heat pumps - capacity at winter design outdoor co	Btu/h	Sensible cooling of	capacity	Btu/h				
Tour parties capacity at miles accegn calacter at		Latent cooling cap	pacity	Btu/h				
Auxiliary heat output capacity	Btu/h	Total cooling capa		Btu/h				
HVAC DUCT DISTRIBUTION	N SYSTEM	DESIGN (UMC	C 601.2)					
Design airflow	CFM	Longest supply duct	:: Ft		erials Used (circle)	Chart motal		
External Static Pressure (ESP)	IWC	Longest return duct:	Ft		t: Duct board, Flex Lined sheet met	al, Other (specify)		
Component Pressure Losses (CPL)	IWC	Total Effective Len	gth (TEL) Ft	Branch Du	ıct: Duct board, Fle	ex Sheet metal		
Available Static Pressure (ASP)	IWC	Friction Rate:	IWC			etal, Other (specify)		
ASP = ESP - CPL		Friction Rate = (ASP	× 100) ÷ TEL					
I declare the load calculation, equipm				rformed bas	ed on the building	g plan listed		
above, I understand the claims made	e on these form	is will be subject to i	review and verification.					
Contractor's Printed Name				Date —				
Contractor's Signature								

Reserved for use by County, Town, Municipality, or Authority having jurisdiction.



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)1

HVAC Designer Responsibilities:

OMB Control Number: 2060-0586

- · Complete one National HVAC Design Report for each system design for a house plan, created for either the specific plan configuration (i.e., elevation, option, orientation, & county) of the home to be certified or for a plan that is intended to be built with different configurations (i.e., different elevations, options, and/or orientations). Visit www.energystar.gov/newhomeshvacdesign and see Footnote 2 for more information.²
- Obtain efficiency features (e.g., window performance, insulation levels, and infiltration rate) from the builder or Rater.³

• Provi	de the completed National HVAC Design Re	port to the	builder or	credentiale	ed HVAC c	ontractor a	and to the F	Rater.		
1. Desig	n Overview									
1.1 Des	gner Name: <u>Engr Rahaman</u>		De	esigner cor	npany:				Date: October	22, 2025
1.2 Sele	ct which party you are providing these desig	n services	to:	☐ Bui	lder	or		redentiale	d HVAC conf	tractor
1.3 Nam	ne of company you are providing these desig	n services	to (if differ	ent than It	em 1.1):					
1.4 Area	a that system serves:		Jpper-leve	ı 🗆	Lower-lev	el [Other			
	ooling system for a temporary occupant load		••	☐ Yes	_					
	se plan: _499 Jay Windom Martin Residen		es@meckb	ox to indica			m desian is	s site-spec	ific or part of	a group: 2
	Site-specific design. Option(s) & elevation		_			,				3 1- 1
	Group design. Group #: out of			for this hou	ıse plan	Configura	ation model	led:		
	ling Unit Mechanical Ventilation System [Designer Verified
Airflow										1
	2.1 Ventilation airflow design rate & run-tim	ne meet the	e requirem	ents of AS	HRAE 62.2	2-2010 or la	ater. ⁹			V
	2.2 Ventilation airflow rate required by 62.2				CFM					
	2.3 Design for this system: Vent. airflow ra					minute	s Cycle tin	ne:	minutes	_
System	Type & Controls:		_ 0							
Cyclo	2.4 Specified system type:	noly \square	Exhaust		Balanced					_
	2.5 Specified control location:	, Pi,	Extradot		Jaiarrood	(e a	Master ba	th utility ro	nom)	
	2.6 Specified controls allow the system to	nnerate au	tomatically	without o	ccupant int		Waster ba	ar, durity re	, oiii)	
	Specified controls include a readily-accobvious (e.g., a label is required for a terminal controls.)	essible ve	ntilation ov	erride and	a label ha	s also bee			ion is not	
	2.8 For any outdoor air inlet designed to correstrict airflow using a motorized damp	nnect to a	ducted ret	urn of the	HVAC syst	tem, specif	ied control		cally	
Sound:	2.9 The fan of the specified system is rate			-				ted 11		
Efficien	· · ·	<u>u _ 0 00110</u>	o ii iiitoiiiii	ttorit uriu _	1 30110 11	oor tiir ta oa o	, or exemp	tou.		
Linoidii	2.10 If Vent System controller operates the 4.7 is ECM / ICM or the controls will re									
	2.11 If bathroom fans are specified as part									
Air Inlo	Location: (Complete this section if syste			•						□ N/A
All lille	2.12 Inlet pulls ventilation air directly from a				•			elling unit		
	2.13 Inlet is ≥ 2 ft. above grade or roof dec					•	-	•	(o.a.	
	stack, vent, exhaust, vehicles) not exitin	g the roof,	and <u>></u> 3 ft.	from knov	vn sources	exiting the	e roof. 15	II Sources	(e.g.,	
	n-by-Room Heating & Cooling Loads 16									
	m-by-room loads calculated using: Unab					SHRAE FU	ındamental	s U Othe	er per AHJ ¹⁷	-
	or design temperatures used in loads are 70									
	loor design temperatures used in loads:(Se nty & State, or US Territory, selected:	ee Footnote	e 18 and w	ww.energy 			emps) ¹⁸ 0°F Hea	ating seaso	on: <u>40</u> °F	-
3.4 Num	ber of occupants used in loads: 19	32								-
3.5 Con	ditioned floor area used in loads: 20	<u>1810</u>			s	q. Ft.				-
3.6 Win	dow area used in loads: ²¹	41			S	q. Ft.				-
3.7 Pred	Iominant window SHGC used in loads: 22	0.62								-
3.8 Infilt	ration rate used in loads: ²³	Summer	0			Winter:	0			-
3.9 Mec	hanical ventilation rate used in loads:	405			С	FM				-
Loads A	At Design Conditions (kBtuh)	N	NE	E	SE	S	sw	W	NW	-
	3.10 Sensible heat gain (By orientation ²⁴)	28.6	29.9	30.2	29.1	28.8	30.1	31.4	30.8	-
Cooling	3.11 Latent heat gain (Not by orientation)	13.1	•	•	•		•	•	•	-
Jooning	3.12 Total heat gain (By orientation ²⁴)	41.7	43	43.3	42.2	41.9	43.2	44.5	43.9	-
	3.13 Maximum - minimum total heat gain (It					tuh	Variation		kBtuh ^{24, 25}	abla
Heating	3.14 Total heat loss (Not by orientation)	27.1					•			-



OMB Control Number: 2060-0586

ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)¹

4. Heating & Cooling Equipm	ent Selection ¹⁶							Designer Verified
4.1 Equipment selected per AC	CA Manual S (se	e Footnote 25 &	26) 26, 27					\Box
Air Conditioner / Heat Pump (Complete if air conditioner or heat pump will be installed; otherwise check "N/A")							□ N/A	
4.2 Equipment type:	☐ Coo	oling-only air cor	nditioner or		Cooling & h	eating heat pum	np	-
4.3 Condenser manufacturer &	model:	GOOD	MAN, Heat P	ump:C	CHPF3743C6+	outdoor unit:G	SX160421F	-
4.4 Evaporator / fan coil manufa	acturer & model:	,						-
4.5 AHRI reference #: ²⁸								_
4.6 Rated cooling efficiency: 29	16 SEER				Rated heatin	a efficiency:		_
4.7 Evaporator fan type:	☐ PSC	ПЕ	ECM / ICM	П	Other:	<u>, ,</u>		
4.8 Compressor type:			wo-speed	一一	Variable-spe	ed		_
4.9 Latent capacity at design co			•	ta: 31	0	<u> </u>	kBtu	ıh -
4.10 Sensible capacity at design							kBtu	
4.11 Total capacity at design co			•		42		kBtu	
4.12 Air-source heat pump capa			kBtuh	ш.	At 47°F:	0 kBtuh	N	
4.13 Cooling sizing % = Total ca	,			eat ga				
4.14 Complete this item if Cond							A": 32	/A
4.14.1 Load sensible heat							= 69 %	_
4.14.2 HDD / CDD ratio (\								
4.15 Check box of applicable co						<u> </u>	,	<u> </u>
Equipment Type (Per Item 4.2)	&			Com	npressor Type	(Per Item 4.8)		
Climate Condition (Per Item 4.1		Single-Spee	d		Two-Spe	ed	Variable-	Speed
For Cooling-Only Equipment or For Cooling Mode of Heat Pum	p in	Recommended: Allowed: 90			Recommend Allowed: 9	ed: 90 - 120%	Recommend	led: 90 - 130%
Condition A Climate		Allowed, 90	- 130%		Allowed. 8	0 - 140%	Allowed. 8	0 - 100%
For Cooling Mode of Heat Pum Condition B Climate	p in	90% - 100%, plu	ıs 15 kBtuh		90% - 100%,	plus 15 kBtuh	90% - 100%,	, plus 15 kBtuh
4.16 Cooling sizing % (4.13) is	within cooling sizi	na limit (4.15)						
Furnace (Complete if furnace			k "N/A")					
4.17 Furnace manufacturer & m		MAN, Heat Pun	,	C6+.c	outdoor unit:G	SX160421F.		-
4.18 Rated heating efficiency:		0		AFI				-
4.19 Total capacity: 33		12	kBtuh	_				-
4.20 Heating sizing % = Total c	apacity (Item 4.19) divided by tota	– al heat loss (It	em 3.1	14): 155 °	%		
4.21 Check box of applicable he		· •	•		,			-
	or Heating Only				Wh	en Paired With (Coolina	
	0 - 140%			71 R			Allowed: 100 – 400%	%
4.22 Heating sizing % (4.20) is		ing limit (4.21)	_					\Box
	heating or coolin		l be installed v	vith du	ucts: otherwise	check "N/A") 16	i	□ N/A
5.1 Duct system designed for the		•						
5.2 Design HVAC fan airflow: 34			•			CFM Heating m	node <u>286</u> CFN	л <u> </u>
5.3 Design HVAC fan speed se	tting (e.g., low, m	edium, high): 35	Coc	ling m	node	Heating i	mode	_
5.4 Design total external static	oressure (corresp	onding to the m	ode with the h	igher	airflow in Item	5.2): ³⁶ 0	_ IWC	-
5.5 Room-by-room design airflo	ws documented b	pelow (which mu	ust sum to the	mode	with the higher	er airflow in Item	5.2) 37, 38	-
Room Name	Design Airflow (CFM)	Room Name		D	esign Airflow (CFM)	Room Name		Design Airflow (CFM)
1 Basement Mechanical	39	12				23		
2 Basement Theater	510	13				24		
3 Basement Storage	61	14				25		
4 Basement Bedroom	169	15				26		
5 Basement Bathroom	57 75	16 17		+		27 28		
6 Basement Flex Room 7 Basement Pumproom	132	18		+		29		
8 Basement Lower Courtyaed	87	19		+		30		
9		20		\top		31		
10		21				32		
11		22				Total for all roo	nms	1131

Page 2 of 5 EPA Form Number: 5900-426



ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)¹

HVAC Designer Responsibilities:

OMB Control Number: 2060-0586

- Complete one National HVAC Design Report for each system design for a house plan, created for either the specific plan configuration (i.e., elevation, option, orientation, & county) of the home to be certified or for a plan that is intended to be built with different configurations (i.e., different elevations, options, and/or orientations). Visit www.energystar.gov/newhomeshvacdesign and see Footnote 2 for more information.²
- Obtain efficiency features (e.g., window performance, insulation levels, and infiltration rate) from the builder or Rater.³

• Provi	de the completed National HVAC Design Re	port to the	builder or	credentiale	ed HVAC c	ontractor a	nd to the F	Rater.		
1. Desig	n Overview									
1.1 Desi	gner Name:		De	esigner cor	npany:				Date:	
1.2 Sele	ct which party you are providing these desig			☐ Buil	lder	or		redentiale	d HVAC cont	tractor
1.3 Nam	e of company you are providing these desig	n services	to (if differ	ent than Ite	em 1.1):					
	that system serves: Whole-house		Jpper-leve		Lower-lev	el [Other			
1.5 ls cc	oling system for a temporary occupant load	2 4		Пуе	s □ No					
1.6 Hous	se plan:		Check b	ox to indica	ate whethe	r the svste	m desian is	site-spec	ific or part of	a group: 2
	Site-specific design. Option(s) & elevation	n(s) modele	ed:			,	J	•	'	0 1
	Group design. Group #:out of							ed:		
2. Dwell	ing Unit Mechanical Ventilation System D	Design ("V	ent Syste	m") ^{5, 6, 7} (& Inlets in	Return Di	uct ⁸			Designer Verified
Airflow:										
	2.1 Ventilation airflow design rate & run-tim	ne meet the	e requirem	ents of ASI	HRAE 62.2	2-2010 or la	ater. ⁹			
	2.2 Ventilation airflow rate required by 62.2	for a cont	inuous sys	tem	CFM					-
	2.3 Design for this system: Vent. airflow ra		-		cycle:	minute	s Cycle tim	ne:	minutes	-
System	Type & Controls:		_	·	<u> </u>		,			'
	2.4 Specified system type: Sup	ply 🔲	Exhaust		Balanced					_
	2.5 Specified control location:	·				(e.g.,	Master bat	h. utility ro	oom)	_
		operate au	tomatically	without o	ccupant int			, ,	,	
2.9 For any outdoor air inlet decigned to connect to a dusted return of the HVAC cyctem, anacified controls outcomptically										
Sound:										
Efficien	cy:									
	2.10 If Vent System controller operates the 4.7 is ECM / ICM or the controls will re	HVAC far	n, then HV/ un-time by	AC fan ope	ration is ing for HVAC	termittent a	and either t	he fan typ ooling hou	e in Item rs. ¹²	
	2.11 If bathroom fans are specified as part	of the syst	tem, then t	hey are EN	IERGY ST	AR certifie	d. ¹³			
Air Inlet	Location: (Complete this section if syste	m has a sr	ecified air	inlet locati	on: otherwi	ise check "	'N/A") ¹⁴			□ N/A
7	2.12 Inlet pulls ventilation air directly from o	•						ellina unit		
	2.13 Inlet is ≥ 2 ft. above grade or roof dec					•	-	•	(e a	
	stack, vent, exhaust, vehicles) not exitin	g the roof,	and <u>></u> 3 ft.	from knov	n sources	exiting the	roof. 15		(0.9.,	
	n-by-Room Heating & Cooling Loads 16							<u> </u>		
3.1 Rooi	m-by-room loads calculated using: 🔲 Unab	ridged AC	CA Manual	J v8 [2013 AS	SHRAE Fu	ndamental	s 🔲 Othe	er per AHJ ¹⁷	-
	or design temperatures used in loads are 70									
3.3 Outo Cou	loor design temperatures used in loads: (Senty & State, or US Territory, selected:	e Footnote	e 18 and w		star.gov/h\ Cooling se			ating seas	on:°F	-
3.4 Num	ber of occupants used in loads: 19									_
	•				So	a. Ft.				_
	3.5 Conditioned floor area used in loads: 20 Sq. Ft 3.6 Window area used in loads: 21 Sq. Ft									
	ominant window SHGC used in loads: ²²					4. 1				_
	ration rate used in loads: ²³	Summer:	,			Winter:				_
	nanical ventilation rate used in loads:	Outilition.			C	FM				
	at Design Conditions (kBtuh)	N	NE	E	SE	s	sw	w	NW	_
Loaus F	3.10 Sensible heat gain (By orientation ²⁴)	14	141	_	JL.		3**		1444	_
0	3.11 Latent heat gain (Not by orientation)		l .	l .		I				_
Cooling	3.12 Total heat gain (By orientation)									_
	3.13 Maximum - minimum total heat gain (It	em 3 12\ a	across orie	⊥ ntations =	kR:	⊥ tuh	Variation	nis < 6	⊥ kBtuh ^{24, 25}	
Heating	3.14 Total heat loss (Not by orientation)							0		-
. rouning	(I								1



OMB Control Number: 2060-0586

ENERGY STAR Single-Family New Homes National HVAC Design Report, Version 3 / 3.1 / 3.2 (Rev. 13)¹

4. Heating & Cooling Equipm	nent Selection ¹⁶							Designe Verified
4.1 Equipment selected per ACCA Manual S (see Footnote 25 & 26) ^{26, 27}								
Air Conditioner / Heat Pump (Complete if air conditioner or heat pump will be installed; otherwise check "N/A")								□N/A
4.2 Equipment type:	☐ Cod	oling-only air cor	nditioner or		Cooling & h	eating heat pun	ıp	-
4.3 Condenser manufacturer &	model:							-
4.4 Evaporator / fan coil manufa	acturer & model:							-
4.5 AHRI reference #: ²⁸								-
4.6 Rated cooling efficiency: 29		/			_ Rated heatin	g efficiency:		
4.7 Evaporator fan type:	☐ PSC		CM / ICM		Other:			-
4.8 Compressor type:	Single	-speed 🔲 T	wo-speed		Variable-spe	ed		-
4.9 Latent capacity at design co	onditions, from OE	M expanded pe	erformance da	ta: ³¹			kBtu	h -
4.10 Sensible capacity at desig	n conditions, from	OEM expanded	d performance	data	31		kBtu	h -
4.11 Total capacity at design co	onditions, from OE	M expanded pe	erformance da	ta: ³¹			kBtu	h -
4.12 Air-source heat pump capa	acity: At 17°	F: k	«Btuh		At 47°F:	kBtuh	□ N	′A -
4.13 Cooling sizing % = Total c			ximum total he	eat ga	in (Item 3.12):			
4.14 Complete this item if Cond	• • •	· · · · · · · · · · · · · · · · · · ·			. ,		A": 32 □ N	'A
4.14.1 Load sensible heat							= %	_
4.14.2 HDD / CDD ratio (\						· · · · · · · · · · · · · · · · · · ·	n) =	
4.15 Check box of applicable co						-		_
Equipment Type (Per Item 4.2)				Com	pressor Type	(Per Item 4.8)		
Climate Condition (Per Item 4.1		Single-Spee	d		Two-Spe	•	Variable-	Speed
For Cooling-Only Equipment or For Cooling Mode of Heat Pum		Recommended:		П		ed: 90 - 120%		ed: 90 - 130%
Condition A Climate	· -	Allowed: 90	- 130%		Allowed: 9	0 - 140%	Allowed: 9	0 - 160%
For Cooling Mode of Heat Pum	p in							
Condition B Climate		90% - 100%, plu	is 15 kBtuh	Ш	90% - 100%,	plus 15 kBtuh	90% - 100%,	plus 15 kBtuh
4.16 Cooling sizing % (4.13) is	within cooling sizi	ng limit (4.15)						
Furnace (Complete if furnace	e will be installed;	otherwise check	k "N/A")					□ N/A
4.17 Furnace manufacturer & n	nodel:							-
4.18 Rated heating efficiency:				_ AFI	JE			-
4.19 Total capacity: 33			_ kBtuh					-
4.20 Heating sizing % = Total c	<u> </u>	· · · · · · · · · · · · · · · · · · ·		em 3.	14):	/6		-
4.21 Check box of applicable he		from chart belov	V :					-
When Used f	or Heating Only				Wh	en Paired With	Cooling	
	0 - 140%			R	ecommended	100 – 140% A	Allowed: 100 – 400%	6
4.22 Heating sizing % (4.20) is								
	heating or coolin					check "N/A") 16	i	□ N/A
5.1 Duct system designed for the		cted in Section	•					. 🗀
5.2 Design HVAC fan airflow: 34							nodeCFM	
5.3 Design HVAC fan speed se							mode	
5.4 Design total external static 5.5 Room-by-room design airflo								-
, ,	Design Airflow	Room Name	ist sum to the		esign Airflow	Room Name	5.2) 37, 30	Design Airflow
Room Name	(CFM)				(CFM)			(CFM)
2		13		-		23		
3		14		-		25		
4		15		+		26		
5		16				27		
6		17				28		
7		18				29		
8		19		\perp		30		
9		20		_		31		
10		21 22		+		Total for all ro	oms	

Revised 02/01/2024 OMB Control Expiration Date: 01/31/2024 Page 2 of 5 EPA Form Number: 5900-426